




Caring for the environment and creating safer workplaces

## Report for the Periodic Monitoring of Emissions to Atmosphere

# Wyndeham Heron Ltd

Operator:	Wyndeham Heron Ltd
Permit Number:	MLD/EPR/A2/001
Installation:	Printworks
Monitoring Dates:	15-16 October & 22 November 2012
Site Address:	The Bethnal Complex Colchester Road Maldon CM9 4NW

Report Number:	J 5319
Version:	2
Date of Report:	3 December 2012
Report Author:	Mr M Ropka
MCERTS Registration N°:	MM 06 761
MCERTS Level:	Level 2 (TE1, TE2, TE3, TE4)

Report Approved by:	Mr D Fisher
MCERTS Registration N°:	MM 08 963
MCERTS Level:	MCERTS Level 2 (TE1, TE3, TE4)
Function:	Environmental Consultant
Signed:	

---

<b>Contents</b>	<b>Page Number</b>
<b>Part 1 : Executive Summary</b>	
1.1 Monitoring Objectives	3
1.2 Monitoring Results	4
1.3 Operating Information	8
1.4 Monitoring Deviations	9
<b>Part 2 : Supporting Information</b>	
2.1 Appendix 1 : General Information	10
2.2 Appendix 2 : Rotoman 1 Lower Results and Calculations	11
2.3 Appendix 3 : Rotoman 1 Upper Results and Calculations	17
2.4 Appendix 4 : Rotoman 2 Lower Results and Calculations	23
2.5 Appendix 5 : Rotoman 2 Upper Results and Calculations	29
2.6 Appendix 6 : Rotoman 3 Lower Results and Calculations	35
2.7 Appendix 7 : Rotoman 3 Upper Results and Calculations	41
2.8 Appendix 8 : Lithoman 1 Results and Calculations	47
2.9 Appendix 9 : Compactor Results and Calculations	53

## Part 1: Executive Summary

### 1.1 Monitoring Objectives

Wyndeham Heron operate several printing lines that have the potential to release controlled substances to atmosphere, and are subject to authorisation under the Environmental Permitting Regulations (EPR, 2010). Under the act, Local Authorities regulate the printing processes with guidance from the Sector Guidance Note SG6: Surface Treatment using Solvents.

In order for Wyndeham Heron to comply with its annual emission limits they have requested that Envirocare Technical Consultancy undertake a monitoring exercise on all of the thermal oxidiser abatement units and from the waste transport system compactor. The methodologies and results obtained form the basis of this report.

The three Rotoman presses have two print lines that run simultaneously and are located one above the other, each press has its own dryer, each with a duct exiting the dryer and emitting vertically alongside one another. The Lithoman 1 Press has a dedicated dryer.

#### Emission Point Identification

Substances to Be Monitored	Rotoman 1		Rotoman 2		Rotoman 3		Lithoman 1	Compactor
	Lower	Upper	Lower	Upper	Lower	Upper		
CO	✓	✓	✓	✓	✓	✓	✓	
NOx	✓	✓	✓	✓	✓	✓	✓	
VOCs	✓	✓	✓	✓	✓	✓	✓	
Moisture (for correction)	✓	✓	✓	✓	✓	✓	✓	
Total Particulate Matter								✓
<b>Special requirements</b>	None							

Opinions and interpretations expressed within this report are outside the scope of Envirocare Technical Consultancies MCERTS and UKAS accreditation.

## 1.2 Monitoring Results

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty as % of ELV (95% confidence)	Reference Conditions	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation for use of Method	Operating Status
Rotoman 1 Lower	Carbon Monoxide	100	<b>40.8</b>	mg/Nm <sup>3</sup>	2.8%	273K, 101.3kPa, WET	15/10/12	14:00-15:05	BS EN 15058	MCERTS	Normal
	Oxides of Nitrogen (as NO <sub>x</sub> )	100	<b>57.2</b>	mg/Nm <sup>3</sup>	2.5%	273K, 101.3kPa, WET	15/10/12	14:00-15:05	BS EN 14792	MCERTS	Normal
	Total VOC's	20	<b>4.9</b>	mg/Nm <sup>3</sup>	11.2%	273K, 101.3kPa, WET	15/10/12	14:00-15:05	BS EN 12619	MCERTS	Normal
	Moisture Content	None	<b>5.7</b>	%	-	273K, 101.3kPa	15/10/12	14:37-15:07	US EPA M4	ISO 17025	Normal
	Volumetric Flowrate	None	<b>4628.9</b>	Nm <sup>3</sup> /Hr	-	273K, 101.3kPa	22/11/12	~09:00	BS EN 13284	MCERTS	Normal

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty as % of ELV (95% confidence)	Reference Conditions	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation for use of Method	Operating Status
Rotoman 1 Upper	Carbon Monoxide	100	<b>35.6</b>	mg/Nm <sup>3</sup>	2.6%	273K, 101.3kPa, WET	15/10/12	15:36-18:04	BS EN 15058	MCERTS	Normal
	Oxides of Nitrogen (as NO <sub>x</sub> )	100	<b>74.6</b>	mg/Nm <sup>3</sup>	2.9%	273K, 101.3kPa, WET	15/10/12	15:36-18:04	BS EN 14792	MCERTS	Normal
	Total VOC's	20	<b>7.5</b>	mg/Nm <sup>3</sup>	11.2%	273K, 101.3kPa, WET	15/10/12	15:36-18:04	BS EN 12619	MCERTS	Normal
	Moisture Content	None	<b>4.8</b>	%	-	273K, 101.3kPa	15/10/12	17:07-17:29	US EPA M4	ISO 17025	Normal
	Volumetric Flowrate	None	<b>4473.9</b>	Nm <sup>3</sup> /Hr	-	273K, 101.3kPa	22/11/12	~09:20	BS EN 13284	MCERTS	Normal

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty as % of ELV (95% confidence)	Reference Conditions	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation for use of Method	Operating Status
Rotoman 2 Lower	Carbon Monoxide	100	47.2	mg/Nm <sup>3</sup>	2.4%	273K, 101.3kPa, WET	16/10/12	10:40-13:00	BS EN 15058	MCERTS	Normal
	Oxides of Nitrogen (as NO <sub>x</sub> )	100	59.1	mg/Nm <sup>3</sup>	2.2%	273K, 101.3kPa, WET	16/10/12	10:40-13:00	BS EN 14792	MCERTS	Normal
	Total VOC's	20	3.0	mg/Nm <sup>3</sup>	4.3%	273K, 101.3kPa, WET	16/10/12	10:40-13:00	BS EN 12619	MCERTS	Normal
	Moisture Content	None	5.1	%	-	273K, 101.3kPa	16/10/12	14:20-14:46	US EPA M4	ISO 17025	Normal
	Volumetric Flowrate	None	3338.1	Nm <sup>3</sup> /Hr	-	273K, 101.3kPa	22/11/12	~09:40	BS EN 13284	MCERTS	Normal

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty as % of ELV (95% confidence)	Reference Conditions	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation for use of Method	Operating Status
Rotoman 2 Upper	Carbon Monoxide	100	55.3	mg/Nm <sup>3</sup>	2.7%	273K, 101.3kPa, WET	16/10/12	13:09-15:19	BS EN 15058	MCERTS	Normal
	Oxides of Nitrogen (as NO <sub>x</sub> )	100	53.5	mg/Nm <sup>3</sup>	2.0%	273K, 101.3kPa, WET	16/10/12	13:09-15:19	BS EN 14792	MCERTS	Normal
	Total VOC's	20	5.1	mg/Nm <sup>3</sup>	4.3%	273K, 101.3kPa, WET	16/10/12	13:09-15:19	BS EN 12619	MCERTS	Normal
	Moisture Content	None	6.4	%	-	273K, 101.3kPa	16/10/12	15:10-15:40	US EPA M4	ISO 17025	Normal
	Volumetric Flowrate	None	2320.6	Nm <sup>3</sup> /Hr	-	273K, 101.3kPa	22/11/12	~10:00	BS EN 13284	MCERTS	Normal

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty as % of ELV (95% confidence)	Reference Conditions	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation for use of Method	Operating Status
<b>Rotoman 3 Lower</b>	Carbon Monoxide	100	<b>59.3</b>	mg/Nm <sup>3</sup>	2.8%	273K, 101.3kPa, WET	16/10/12	11:40-12:40	BS EN 15058	MCERTS	Normal
	Oxides of Nitrogen (as NO <sub>x</sub> )	100	<b>51.7</b>	mg/Nm <sup>3</sup>	1.9%	273K, 101.3kPa, WET	16/10/12	11:40-12:40	BS EN 14792	MCERTS	Normal
	Total VOC's	20	<b>1.9</b>	mg/Nm <sup>3</sup>	5.5%	273K, 101.3kPa, WET	16/10/12	11:40-12:40	BS EN 12619	MCERTS	Normal
	Moisture Content	None	<b>7.2</b>	%	-	273K, 101.3kPa	16/10/12	11:39-12:09	US EPA M4	ISO 17025	Normal
	Volumetric Flowrate	None	<b>3991.6</b>	Nm <sup>3</sup> /Hr	-	273K, 101.3kPa	22/11/12	~10:20	BS EN 13284	MCERTS	Normal

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty as % of ELV (95% confidence)	Reference Conditions	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation for use of Method	Operating Status
<b>Rotoman 3 Upper</b>	Carbon Monoxide	100	<b>60.5</b>	mg/Nm <sup>3</sup>	2.9%	273K, 101.3kPa, WET	16/10/12	13:00-14:00	BS EN 15058	MCERTS	Normal
	Oxides of Nitrogen (as NO <sub>x</sub> )	100	<b>53.2</b>	mg/Nm <sup>3</sup>	2.0%	273K, 101.3kPa, WET	16/10/12	13:00-14:00	BS EN 14792	MCERTS	Normal
	Total VOC's	20	<b>1.9</b>	mg/Nm <sup>3</sup>	5.5%	273K, 101.3kPa, WET	16/10/12	13:00-14:00	BS EN 12619	MCERTS	Normal
	Moisture Content	None	<b>7.2</b>	%	-	273K, 101.3kPa	16/10/12	12:24-12:54	US EPA M4	ISO 17025	Normal
	Volumetric Flowrate	None	<b>3853.2</b>	Nm <sup>3</sup> /Hr	-	273K, 101.3kPa	22/11/12	~10:40	BS EN 13284	MCERTS	Normal

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty as % of ELV (95% confidence)	Reference Conditions	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation for use of Method	Operating Status
Lithoman 1	Carbon Monoxide	100	<b>64.8</b>	mg/Nm <sup>3</sup>	3.4%	273K, 101.3kPa, WET	15/10/12	16:31-18:20	BS EN 15058	MCERTS	Normal
	Oxides of Nitrogen (as NO <sub>x</sub> )	100	<b>50.5</b>	mg/Nm <sup>3</sup>	2.0%	273K, 101.3kPa, WET	15/10/12	16:31-18:20	BS EN 14792	MCERTS	Normal
	Total VOC's	20	<b>0.0</b>	mg/Nm <sup>3</sup>	5.5%	273K, 101.3kPa, WET	15/10/12	16:31-18:20	BS EN 12619	MCERTS	Normal
	Moisture Content	None	<b>8.7</b>	%	-	273K, 101.3kPa	15/10/12	18:20-18:40	US EPA M4	ISO 17025	Normal
	Volumetric Flowrate	None	<b>5910.3</b>	Nm <sup>3</sup> /Hr	-	273K, 101.3kPa	22/11/12	~8:40	BS EN 13284	MCERTS	Normal

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty as % of ELV (95% confidence)	Reference Conditions	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation for use of Method	Operating Status
Compactor	Total Particulate Matter	50*	<b>1.9</b>	mg/Nm <sup>3</sup>	-	273K, 101.3kPa	12/10/11	10:35 – 13:54	MDHS 14/3	None	Normal

\*Assumed

### 1.3 Operating Information

Emission Point Reference	Date	Process Type	Process Duration	Fuel	Feedstock	Abatement	Press Speed	Comparison of Operator CEMS and Periodic Monitoring Results			
								Substance	CEMS Results	Periodic Monitoring Results	Units
Rotoman 1 Lower	15/10/12	Offset Lithographic Printing	Batch.	Natural Gas	Paper and Ink	Thermal Oxidiser	37,000 cph	N/A	N/A	N/A	N/A
Rotoman 1 Upper	15/10/12	Offset Lithographic Printing	Batch.	Natural Gas	Paper and Ink	Thermal Oxidiser	26,000 cph	N/A	N/A	N/A	N/A
Rotoman 2 Lower	16/10/12	Offset Lithographic Printing	Batch.	Natural Gas	Paper and Ink	Thermal Oxidiser	43,000 cph	N/A	N/A	N/A	N/A
Rotoman 2 Upper	16/10/12	Offset Lithographic Printing	Batch.	Natural Gas	Paper and Ink	Thermal Oxidiser	Unknown	N/A	N/A	N/A	N/A
Rotoman 3 Lower	16/10/12	Offset Lithographic Printing	Batch.	Natural Gas	Paper and Ink	Thermal Oxidiser	Unknown	N/A	N/A	N/A	N/A
Rotoman 3 Upper	16/10/12	Offset Lithographic Printing	Batch.	Natural Gas	Paper and Ink	Thermal Oxidiser	Unknown	N/A	N/A	N/A	N/A
Lithoman 1	15/10/12	Offset Lithographic Printing	Batch.	Natural Gas	Paper and Ink	Thermal Oxidiser	Unknown	N/A	N/A	N/A	N/A
Compactor	16/10/12	Collection of offcuts from binding	Continuous	None	Paper offcuts	Bag Filter	N/A	N/A	N/A	N/A	N/A

## 1.4 Monitoring Deviations

Emission Point Reference	Substance Deviations	Monitoring Deviations	Other Relevant Issues
Rotoman 1 Lower	None	None	None
Rotoman 1 Upper	None	None	None
Rotoman 2 Lower	None	None	None
Rotoman 2 Upper	None	None	None
Rotoman 3 Lower	None	None	None
Rotoman 3 Upper	None	None	None
Lithoman 1	None	None	None
Compactor	None	None	None

## Part 2: Supporting Information

### 2.1 Appendix 1: General Information

#### 2.1.1 Monitoring organisation staff details

Personnel	Function in monitoring campaign	MCERTS Level	MCERTS Number
Mr M Ropka	Team Leader	MCERTS Level 2 (TE1, TE2, TE3, TE4)	MM 06 761
Mr D Fisher	Technician	MCERTS Level 2 (TE1, TE3, TE4)	MM 08 963
Mr C G Mann	Team Leader	MCERTS Level 2 (TE1, TE2, TE3, TE4)	MM 06 695
Mr A R May	Technician	MCERTS Level 2 (TE1, TE3, TE4)	MM 05 626

#### 2.1.2 Monitoring Methods

Pollutant Species	Standard	Technique	Envirocare Internal Procedure
Total VOC's	BS EN 12619	FID	ETC-M-03
Carbon Monoxide	BS EN 15058	NDIR	ETC-M-25
Oxides of Nitrogen	BS EN 14792	Chemiluminescence	ETC-M-25
Particulates	MDHS 14/3	Gravimetric	SM-05
Stack Temperature + Velocity	BS EN 13284	Pitot Tube + Thermocouple	ETC-M-46

#### 2.1.3 Equipment Checklist

Equipment ID	Model Number	Purpose
Horiba 1	Horiba PG250	Multi component gas analyser
Horiba 2	Horiba PG250	Multi component gas analyser
Sig 1	Signal 3030pm	Flame Ionisation Detector
Sig 3	Signal 3030pm	Flame Ionisation Detector
HL3	Signal Heated Line	PTFE Cored heated sample line
HL6	-	PTFE Cored heated sample line
HL7	-	PTFE Cored heated sample line
HL8	-	PTFE Cored heated sample line
GPU4	MAK10	Sample gas conditioner
GPU5	MAK10	Sample gas conditioner

---

## 2.2 Appendix 2: Rotoman 1 Lower Results and Calculations

### 2.2.1 Photograph of the sampling location and positions



## 2.2.2 Flow criteria measurements

Stack reference: **Rotoman 1 Lower** Date: **22/11/2012**  
 Duct dimensions: **60.0 cm**  
 Local barometric pressure: **1017 mbar**  
 Ambient Temperature: **23 °C** Pitot Coefficient = **0.822**  
 Micromanometer Calibration (K; mbar) = **289 1000**

Sample port (A)	Traverse point	Traverse position (D)	Distance (cm)	Velocity (m/s)		Temp (°C)
				Uncorr.	Corrd.	
Single	A1	0.05	3.0	8.2	9.7	336
	A2	0.15	9.0	8.6	10.2	336
	A3	0.25	15.0	8.3	9.8	336
	A4	0.35	21.0	8.0	9.5	336
	A5	0.45	27.0	8.6	10.2	336
	A6	0.55	33.0	9.0	10.6	336
	A7	0.65	39.0	9.1	10.8	336
	A8	0.75	45.0	8.9	10.5	336
	A9	0.85	51.0	8.4	9.9	336
	A10	0.95	57.0	8.3	9.8	336

<u>Velocity readings (m/s)</u>			
<b>Duct Mean m/s</b>		<b>10.1</b>	
Highest(a)	10.8	Lowest (b)	9.5

<u>Temperature readings</u>			
<b>Duct Mean °C</b>		<b>336</b>	
Duct Mean K 609			
Highest(a)	336.0	Lowest (b)	336.0

<u>Volumetric flow rate</u>			
Duct dimensions	60.0	(cm)	
Duct area	0.283	(m <sup>2</sup> )	
Mean duct velocity	10.1	(m/s)	
Mean duct temperature	336	(°C)	
Ambient pressure	1017	(mbar)	
<b>Vol. Flow rate at stack conditions</b>	<b>10285</b>	<b>(m<sup>3</sup>/hr)</b>	
<b>Vol flow rate corrd.</b>	<b>4628.9</b>	<b>(Nm<sup>3</sup>/hr)</b>	

### 2.2.3 Water vapour measurements

#### MOISTURE TEST FORM

**Client Name:** Wyndeham Heron  
**Job Number:** 5319

**Date:** 15/10/2012

**Stack Reference:** Rotoman 1 Lower

**Ambient Pressure (mbar):** 1005

**Gas Meter Temperature (°C):**

**Stack Temperature (°C):** 342

**Start:** 20

**Gasmeter Coefficient:** 1.000

**End:** 30

**Equipment used:** Pump 59

**Mean:** 25

**Leak Check (l/min) Before:** 0.1

**After:** 0.1

<b>Start Flow Reading (l/min)</b>	1.682	<b>Start Time</b>	14:37:00
<b>End Flow Reading (l/min)</b>	1.636	<b>End Time</b>	15:07:00
<b>Volume Sampled (l)</b>	49.8	<b>Total Time (min)</b>	30
<b>Corrected Volume Sampled (l)</b>	45.2		
<b>Sampling Rate (l/min)</b>	1.659		

	IMPINGER	
	1	2
<b>Start Weight of Impingers (g)</b>	90.0	91.1
<b>End Weight of Impingers (g)</b>	92.3	91
<b>Weight Gain (g)</b>	2.3	-0.1

<b>Total Weight Gain (1+2+3+4) (g)</b>	2.2
<b>Total Weight Gain in litres (l)</b>	2.74

<b>Moisture Content of Gases (g/Nm<sup>3</sup>)</b>	48.6
<b>Moisture Content of Gases (%)</b>	5.71

### 2.2.4 Manual monitoring method - results – calculations

Not applicable.

### 2.2.5 Analysis results

Not applicable.

## 2.2.6 Instrumental gas analyser site calibration measurements

### ANALYSER CALIBRATIONS

#### Combustion Gas and VOC Emissions from Rotoman 1 (15/10/12)

Data entered by: MR

Horiba Analyser: Hor 1

Signal Analyser: Sig 1

Type of Gas	CO		NO		VOCs	
<b>Certified Calibration Values</b>	80.7	ppm +/-2%	49.1	ppm +/-2%	10.13	ppm +/-2%
<b>Response Time T90</b>	8.0	seconds	11.0	seconds	4.00	seconds
<b>Period</b>						
Span PreCal direct to analyser	80.9	ppm	49.2	ppm	-	ppm
Zero PreCal through sample line	-0.2	ppm	0.0	ppm	0.0	ppm
Span PreCal through sample line	80.4	ppm	48.9	ppm	10.1	ppm
Zero PostCal through sample line	0.5	ppm	0.1	ppm	-1.2	ppm
Span PostCal through sample line	79.3	ppm	48.3	ppm	10.3	ppm
Span Drift	1.4	%	1.2	%		
Zero Drift	-0.9	%	-0.2	%		
Is data valid without adjustment	YES		YES			
Does data require adjustment	NO		NO			
Is data invalid	NO		NO			

## 2.2.7 Instrumental gas analyser results


### Gaseous Analysis using Horiba PG 250 & Signal 3030PM Analysers

Wyndeham Heron, Maldon

#### Combustion Gas and VOC Emissions from Rotoman 1 Lower (15/10/12)

	Carbon Monoxide	Oxides of Nitrogen	VOCs	Conversion from ppm to mg/Nm <sup>3</sup> WET		
	CO (ppm)	NOx (ppm)	(ppm)	CO (mg/Nm <sup>3</sup> )	NOx (as NO <sub>2</sub> ) (mg/Nm <sup>3</sup> )	VOCs (mg/Nm <sup>3</sup> )
<b>Average</b>	<b>34.6</b>	<b>29.6</b>	<b>3.0</b>	<b>40.8</b>	<b>57.2</b>	<b>4.9</b>
<b>Maximum</b>	<b>37.8</b>	<b>41.5</b>	<b>5.3</b>	<b>44.6</b>	<b>80.3</b>	<b>8.5</b>
<b>Minimum</b>	<b>23.4</b>	<b>22.5</b>	<b>1.6</b>	<b>27.6</b>	<b>43.6</b>	<b>2.6</b>

### Combustion Gas and VOC Emissions from Rotoman 1 Lower Wyndeham Heron, Maldon (15/10/12)



## 2.2.8 Uncertainty calculations

### UNCERTAINTY OF CARBON MONOXIDE BY HORIBA 1

Reading =	34.6	ppm
Span Gas Certified Value =	80.7	ppm +/-2%
Emission Limit Value	100	mg/Nm <sup>3</sup>

Parameter	Uncertainty criteria	Probability distribution	Divisor	U	U <sup>2</sup>
Repeatability (% of value)	1	Normal	1	0.3460	0.1197
Zero Drift/Lower limit of detection (ppm)	-0.70	Rectangular	1.732	-0.4042	0.1633
Span Drift (ppm)	1.10	Rectangular	1.732	0.6351	0.4034
Linearity (% of value)	1.01	Rectangular	1.732	0.2018	0.0407
Setting Gas Divider (% of value)	0.25	Normal	1	0.0865	0.0075
Interference (% of value)	2.9	Rectangular	1.732	0.5793	0.3356
Span Gas (% of span gasvalue)	1	Rectangular	1.732	0.4659	0.2171
				Sum U <sup>2</sup>	1.29
				<b>Combined Standard Uncertainty (ppm)</b>	1.13
				<b>Expanded Total Uncertainty (ppm) (95% Confidence)</b>	2.22
				<b>Expanded Total Uncertainty as a percentage of emission concentration(95% Confidence)</b>	6.4
				<b>Expanded Total Uncertainty (mg/Nm<sup>3</sup>) (95% Confidence)</b>	2.78
				<b>Expanded Total Uncertainty as a percentage of ELV (95% Confidence)</b>	2.8

### UNCERTAINTY OF OXIDES OF NITROGEN BY HORIBA 1

Reading =	29.6	ppm
Span Gas Certified Value =	49.1	ppm
Emission Limit Value	100	mg/Nm <sup>3</sup>

Parameter	Uncertainty criteria	Probability distribution	Divisor	U	U <sup>2</sup>
Repeatability (% of value)	1	Normal	1	0.2960	0.0876
Zero Drift/Lower limit of detection (ppm)	-0.10	Rectangular	1.732	-0.0577	0.0033
Span Drift (ppm)	0.60	Rectangular	1.732	0.3464	0.1200
Linearity (% of value)	1.41	Rectangular	1.732	0.2410	0.0581
Setting Gas Divider (% of value)	0.25	Normal	1	0.0740	0.0055
Interference (% of value)	1.2	Rectangular	1.732	0.2051	0.0421
Span Gas (% of span gasvalue)	1	Rectangular	1.732	0.2835	0.0804
				Sum U <sup>2</sup>	0.40
				<b>Combined Standard Uncertainty (ppm)</b>	0.63
				<b>Expanded Total Uncertainty (ppm) (95% Confidence)</b>	1.23
				<b>Expanded Total Uncertainty as a percentage of emission concentration(95% Confidence)</b>	4.2
				<b>Expanded Total Uncertainty (mg/Nm<sup>3</sup>) (95% Confidence)</b>	2.53
				<b>Expanded Total Uncertainty as a percentage of ELV (95% Confidence)</b>	2.5

### UNCERTAINTY OF VOC BY SIGNAL 1

Reading =	3.1	ppm as C <sub>3</sub> H <sub>8</sub>
Span Gas =	10.13	ppm +/-2%
Emission Limit Value	20	mg/Nm <sup>3</sup>

Parameter	Uncertainty criteria	Probability distribution	Divisor	U	U <sup>2</sup>
Repeatability (% of value)	1	Normal	1	0.0310	0.0010
Zero Drift/ Detection threshold	1.20	Rectangular	1.732	0.6928	0.4800
Span Drift (ppm)	-0.20	Rectangular	1.732	-0.1155	0.0133
Noise (ppm)	0.1	Rectangular	1.732	0.0577	0.0033
Linearity (% of value)	1.65	Rectangular	1.732	0.0295	0.0009
Setting Gas Divider (% of value)	0.25	Normal	1	0.0078	0.0001
Temperature Drift (% of value)	1	Rectangular	1.732	0.0179	0.0003
Span Gas (% of value)	1	Rectangular	1.732	0.0585	0.0034
				Sum U <sup>2</sup>	0.50
				<b>Combined Standard Uncertainty (ppm as C<sub>3</sub>H<sub>8</sub>)</b>	0.71
				<b>Expanded Total Uncertainty (ppm as C<sub>3</sub>H<sub>8</sub>) (95% Confidence)</b>	1.39
				<b>Expanded Total Uncertainty as a percentage of emission concentration(95% Confidence)</b>	44.8
				<b>Expanded Total Uncertainty (mg/Nm<sup>3</sup> as carbon) (95% Confidence)</b>	2.23
				<b>Expanded Total Uncertainty as a percentage of ELV (95% Confidence)</b>	11.2

## 2.3 Appendix 3: Rotoman 1 Upper Results and Calculations

### 2.3.1 Photograph of the sampling location and positions



### 2.3.2 Flow criteria measurements

Stack reference: **Rotoman 1 Upper** Date: **22/11/2012**  
 Duct dimensions: **60.0 cm**  
 Local barometric pressure: **1017 mbar**  
 Ambient Temperature: **23 °C** Pitot Coefficient = **0.822**  
 Micromanometer Calibration (K; mbar) = **289 1000**

Sample port (A)	Traverse point	Traverse position (D)	Distance (cm)	Velocity (m/s)		Temp (°C)
				Uncorr.	Corrd.	
Single	A1	0.05	3.0	12.0	14.1	331
	A2	0.15	9.0	11.9	14.0	331
	A3	0.25	15.0	10.7	12.6	331
	A4	0.35	21.0	9.8	11.5	331
	A5	0.45	27.0	8.7	10.3	331
	A6	0.55	33.0	7.0	8.2	331
	A7	0.65	39.0	6.4	7.5	331
	A8	0.75	45.0	5.2	6.1	331
	A9	0.85	51.0	5.2	6.1	331
	A10	0.95	57.0	5.3	6.2	331

<u>Velocity readings (m/s)</u>			
<b>Duct Mean m/s</b>		<b>9.7</b>	
Highest(a)	14.1	Lowest (b)	6.1

<u>Temperature readings</u>			
<b>Duct Mean °C</b>		<b>331</b>	
Duct Mean K 604			
Highest(a)	331.0	Lowest (b)	331.0

<u>Volumetric flow rate</u>			
Duct dimensions	60.0	(cm)	
Duct area	0.283	(m <sup>2</sup> )	
Mean duct velocity	9.7	(m/s)	
Mean duct temperature	331	(°C)	
Ambient pressure	1017	(mbar)	
<b>Vol. Flow rate at stack conditions</b>	<b>9859</b>	<b>(m<sup>3</sup>/hr)</b>	
<b>Vol flow rate corrd.</b>	<b>4473.9</b>	<b>(Nm<sup>3</sup>/hr)</b>	

### 2.3.3 Water vapour measurements

#### MOISTURE TEST FORM

**Client Name:** Wyndeham Heron  
**Job Number:** 5319

**Date:** 15/10/2012

**Stack Reference:** Rotoman 1 Upper

**Ambient Pressure (mbar):** 1005

**Stack Temperature (°C):** 347

**Gasmeter Coefficient:** 1.000

**Equipment used:** Pump 59

**Leak Check (l/min) Before:** 0.1

**After:** 0.1

**Gas Meter Temperature (°C):**

**Start:** 20

**End:** 30

**Mean:** 25

<b>Start Flow Reading (l/min)</b>	1.596	<b>Start Time</b>	17:07:00
<b>End Flow Reading (/minl)</b>	1.621	<b>End Time</b>	17:29:00
<b>Volume Sampled (l)</b>	35.4	<b>Total Time (min)</b>	22
<b>Corrected Volume Sampled (l)</b>	32.2		
<b>Sampling Rate (l/min)</b>	1.609		

	IMPINGER	
	1	2
<b>Start Weight of Impingers (g)</b>	91.1	92.3
<b>End Weight of Impingers (g)</b>	92.7	92
<b>Weight Gain (g)</b>	1.6	-0.3

<b>Total Weight Gain (1+2+3+4) (g)</b>	1.3
<b>Total Weight Gain in litres (l)</b>	1.62

<b>Moisture Content of Gases (g/Nm<sup>3</sup>)</b>	40.4
<b>Moisture Content of Gases (%)</b>	4.79

### 2.3.4 Manual monitoring method - results – calculations

Not applicable.

### 2.3.5 Analysis results

Not applicable.

### 2.3.6 Instrumental gas analyser site calibration measurements

#### ANALYSER CALIBRATIONS

#### Combustion Gas and VOC Emissions from Rotoman 1 Upper (15/10/12)

Data entered by: MR

Horiba Analyser: Hor 1

Signal Analyser: Sig 1

Type of Gas	CO		NO		VOCs	
<b>Certified Calibration Values</b>	80.7	ppm +/-2%	49.1	ppm +/-2%	10.13	ppm +/-2%
<b>Response Time T90</b>	8.0	seconds	11.0	seconds	4.00	seconds
<b>Period</b>						
Span PreCal direct to analyser	80.9	ppm	49.2	ppm	-	ppm
Zero PreCal through sample line	-0.2	ppm	0.0	ppm	0.0	ppm
Span PreCal through sample line	80.4	ppm	48.9	ppm	10.1	ppm
Zero PostCal through sample line	0.5	ppm	0.1	ppm	-1.2	ppm
Span PostCal through sample line	79.3	ppm	48.3	ppm	10.3	ppm
Span Drift	1.4	%	1.2	%		
Zero Drift	-0.9	%	-0.2	%		
Is data valid without adjustment	YES		YES			
Does data require adjustment	NO		NO			
Is data invalid	NO		NO			

### 2.3.7 Instrumental gas analyser results


#### Gaseous Analysis using Horiba PG 250 & Signal 3030PM Analysers

Wyndeham Heron, Maldon

#### Combustion Gas and VOC Emissions from Rotoman 1 Upper (15/10/12)

	Carbon Monoxide CO (ppm)	Oxides of Nitrogen NOx (ppm)	VOCs (ppm)	Conversion from ppm to mg/Nm <sup>3</sup> WET		
				CO (mg/Nm <sup>3</sup> )	NOx (as NO <sub>2</sub> ) (mg/Nm <sup>3</sup> )	VOCs (mg/Nm <sup>3</sup> )
<b>Average</b>	<b>29.9</b>	<b>38.2</b>	<b>4.7</b>	<b>35.6</b>	<b>74.6</b>	<b>7.5</b>
<b>Maximum</b>	<b>38.0</b>	<b>45.8</b>	<b>6.5</b>	<b>45.2</b>	<b>89.5</b>	<b>10.4</b>
<b>Minimum</b>	<b>27.1</b>	<b>32.4</b>	<b>3.8</b>	<b>32.3</b>	<b>63.2</b>	<b>6.1</b>

### Combustion Gas and VOC Emissions from Rotoman 1 Upper Wyndeham Heron, Maldon (15/10/12)



## 2.3.8 Uncertainty calculations

### UNCERTAINTY OF CARBON MONOXIDE BY HORIBA 1

Reading =	29.9	ppm
Span Gas Certified Value =	80.7	ppm +/-2%
Emission Limit Value	100	mg/Nm <sup>3</sup>

Parameter	Uncertainty criteria	Probability distribution	Divisor	U	U <sup>2</sup>
Repeatability (% of value)	1	Normal	1	0.2990	0.0894
Zero Drift/Lower limit of detection (ppm)	-0.70	Rectangular	1.732	-0.4042	0.1633
Span Drift (ppm)	1.10	Rectangular	1.732	0.6351	0.4034
Linearity (% of value)	1.01	Rectangular	1.732	0.1744	0.0304
Setting Gas Divider (% of value)	0.25	Normal	1	0.0748	0.0056
Interference (% of value)	2.9	Rectangular	1.732	0.5006	0.2506
Span Gas (% of span gasvalue)	1	Rectangular	1.732	0.4659	0.2171
				Sum U <sup>2</sup>	1.16
				<b>Combined Standard Uncertainty (ppm)</b>	1.08
				<b>Expanded Total Uncertainty (ppm) (95% Confidence)</b>	2.11
				<b>Expanded Total Uncertainty as a percentage of emission concentration(95% Confidence)</b>	7.1
				<b>Expanded Total Uncertainty (mg/Nm<sup>3</sup>) (95% Confidence)</b>	2.64
				<b>Expanded Total Uncertainty as a percentage of ELV (95% Confidence)</b>	2.6

### UNCERTAINTY OF OXIDES OF NITROGEN BY HORIBA 1

Reading =	38.2	ppm
Span Gas Certified Value =	49.1	ppm
Emission Limit Value	100	mg/Nm <sup>3</sup>

Parameter	Uncertainty criteria	Probability distribution	Divisor	U	U <sup>2</sup>
Repeatability (% of value)	1	Normal	1	0.3820	0.1459
Zero Drift/Lower limit of detection (ppm)	-0.10	Rectangular	1.732	-0.0577	0.0033
Span Drift (ppm)	0.60	Rectangular	1.732	0.3464	0.1200
Linearity (% of value)	1.41	Rectangular	1.732	0.3110	0.0967
Setting Gas Divider (% of value)	0.25	Normal	1	0.0955	0.0091
Interference (% of value)	1.2	Rectangular	1.732	0.2647	0.0700
Span Gas (% of span gasvalue)	1	Rectangular	1.732	0.2835	0.0804
				Sum U <sup>2</sup>	0.53
				<b>Combined Standard Uncertainty (ppm)</b>	0.72
				<b>Expanded Total Uncertainty (ppm) (95% Confidence)</b>	1.42
				<b>Expanded Total Uncertainty as a percentage of emission concentration(95% Confidence)</b>	3.7
				<b>Expanded Total Uncertainty (mg/Nm<sup>3</sup>) (95% Confidence)</b>	2.92
				<b>Expanded Total Uncertainty as a percentage of ELV (95% Confidence)</b>	2.9

### UNCERTAINTY OF VOC BY SIGNAL 1

Reading =	4.7	ppm as C <sub>3</sub> H <sub>8</sub>
Span Gas=	10.13	ppm+/-2%
Emission Limit Value	20	mg/Nm <sup>3</sup>

Parameter	Uncertainty criteria	Probability distribution	Divisor	U	U <sup>2</sup>
Repeatability (% of value)	1	Normal	1	0.0470	0.0022
Zero Drift/ Detection threshold	1.20	Rectangular	1.732	0.6928	0.4800
Span Drift (ppm)	-0.20	Rectangular	1.732	-0.1155	0.0133
Noise (ppm)	0.1	Rectangular	1.732	0.0577	0.0033
Linearity (% of value)	1.65	Rectangular	1.732	0.0448	0.0020
Setting Gas Divider (% of value)	0.25	Normal	1	0.0118	0.0001
Temperature Drift (% of value)	1	Rectangular	1.732	0.0271	0.0007
Span Gas (% of value)	1	Rectangular	1.732	0.0585	0.0034
				Sum U <sup>2</sup>	0.51
				<b>Combined Standard Uncertainty (ppm as C<sub>3</sub>H<sub>8</sub>)</b>	0.71
				<b>Expanded Total Uncertainty (ppm as C<sub>3</sub>H<sub>8</sub>) (95% Confidence)</b>	1.39
				<b>Expanded Total Uncertainty as a percentage of emission concentration(95% Confidence)</b>	29.6
				<b>Expanded Total Uncertainty (mg/Nm<sup>3</sup> as carbon) (95% Confidence)</b>	2.24
				<b>Expanded Total Uncertainty as a percentage of ELV (95% Confidence)</b>	11.2

---

## 2.4 Appendix 4: Rotoman 2 Lower Results and Calculations

### 2.4.1 Photograph of the sampling location and positions



## 2.4.2 Flow criteria measurements

Stack reference: **Rotoman 2 Lower** Date: **22/11/2012**  
 Duct dimensions: **50.0 cm**  
 Local barometric pressure: **1017 mbar**  
 Ambient Temperature: **23 °C** Pitot Coefficient = **0.822**  
 Micromanometer Calibration (K; mbar) = **289 1000**

Sample port (A)	Traverse point	Traverse position (D)	Distance (cm)	Velocity (m/s)		Temp (°C)
				Uncorr.	Corrd.	
Single	A1	0.05	2.5	9.3	11.2	357
	A2	0.15	7.5	9.6	11.6	357
	A3	0.25	12.5	9.4	11.3	357
	A4	0.35	17.5	9.1	11.0	357
	A5	0.45	22.5	8.5	10.2	357
	A6	0.55	27.5	7.8	9.4	357
	A7	0.65	32.5	9.3	11.2	357
	A8	0.75	37.5	9.7	11.7	357
	A9	0.85	42.5	9.3	11.2	357
	A10	0.95	47.5	8.2	9.9	357

<u>Velocity readings (m/s)</u>			
<b>Duct Mean m/s</b>		<b>10.9</b>	
Highest(a)	11.7	Lowest (b)	9.4

<u>Temperature readings</u>			
<b>Duct Mean °C</b>		<b>357</b>	
Duct Mean K 630			
Highest(a)	357.0	Lowest (b)	357.0

<u>Volumetric flow rate</u>			
Duct dimensions	50.0	(cm)	
Duct area	0.196	(m <sup>2</sup> )	
Mean duct velocity	10.9	(m/s)	
Mean duct temperature	357	(°C)	
Ambient pressure	1017	(mbar)	
<b>Vol. Flow rate at stack conditions</b>	<b>7673</b>	<b>(m<sup>3</sup>/hr)</b>	
<b>Vol flow rate corrd.</b>	<b>3338.1</b>	<b>(Nm<sup>3</sup>/hr)</b>	

### 2.4.3 Water vapour measurements

#### MOISTURE TEST FORM

**Client Name:** Wyndeham Heron  
**Job Number:** 5319

**Date:** 16/10/2012

**Stack Reference:** Rotoman 2 Lower

**Ambient Pressure (mbar):** 1005

**Gas Meter Temperature (°C):**

**Stack Temperature (°C):** 310

**Start:** 20

**Gasmeter Coefficient:** 1.000

**End:** 30

**Equipment used:** Pump 59

**Mean:** 25

**Leak Check (l/min) Before:** 0.1

**After:** 0.1

<b>Start Flow Reading (l/min)</b>	1.744	<b>Start Time</b>	14:20:00
<b>End Flow Reading (l/min)</b>	1.614	<b>End Time</b>	14:26:00
<b>Volume Sampled (l)</b>	43.7	<b>Total Time (min)</b>	26
<b>Corrected Volume Sampled (l)</b>	39.7		
<b>Sampling Rate (l/min)</b>	1.679		

	IMPINGER	
	1	2
<b>Start Weight of Impingers (g)</b>	89.5	93.2
<b>End Weight of Impingers (g)</b>	91.2	93.2
<b>Weight Gain (g)</b>	1.7	0.0

<b>Total Weight Gain (1+2+3+4) (g)</b>	1.7
<b>Total Weight Gain in litres (l)</b>	2.12

<b>Moisture Content of Gases (g/Nm<sup>3</sup>)</b>	42.8
<b>Moisture Content of Gases (%)</b>	5.07

### 2.4.4 Manual monitoring method - results – calculations

Not applicable.

### 2.4.5 Analysis results

Not applicable.

## 2.4.6 Instrumental gas analyser site calibration measurements

### ANALYSER CALIBRATIONS

#### Combustion Gas and VOC Emissions from Rotoman 2 (16/10/12)

Data entered by: MR

Horiba Analyser: Hor 1

Signal Analyser: Sig 1

Type of Gas	CO		NO		VOCs	
<b>Certified Calibration Values</b>	80.7	ppm +/-2%	49.1	ppm +/-2%	10.13	ppm +/-2%
<b>Response Time T90</b>	11.0	seconds	11.0	seconds	4.00	seconds
<b>Period</b>						
Span PreCal direct to analyser	79.9	ppm	49.0	ppm	-	ppm
Zero PreCal through sample line	1.0	ppm	0.1	ppm	0.0	ppm
Span PreCal through sample line	80.7	ppm	48.9	ppm	10.1	ppm
Zero PostCal through sample line	1.0	ppm	0.2	ppm	0.4	ppm
Span PostCal through sample line	80.3	ppm	48.9	ppm	10.3	ppm
Span Drift	0.5	%	0.0	%		
Zero Drift	0.0	%	-0.2	%		
Is data valid without adjustment	YES		YES			
Does data require adjustment	NO		NO			
Is data invalid	NO		NO			

## 2.4.7 Instrumental gas analyser results


### Gaseous Analysis using Horiba PG 250 & Signal 3030PM Analysers

Wyndeham Heron, Maldon

#### Combustion Gas and VOC Emissions from Rotoman 2 Lower (16/10/12)

	Carbon Monoxide CO (ppm)	Oxides of Nitrogen NOx (ppm)	VOCs (ppm)	Conversion from ppm to mg/Nm <sup>3</sup> WET		
				CO (mg/Nm <sup>3</sup> )	NOx (as NO <sub>2</sub> ) (mg/Nm <sup>3</sup> )	VOCs (mg/Nm <sup>3</sup> )
<b>Average</b>	<b>39.8</b>	<b>30.3</b>	<b>1.9</b>	<b>47.2</b>	<b>59.1</b>	<b>3.0</b>
<b>Maximum</b>	<b>62.4</b>	<b>41.7</b>	<b>3.0</b>	<b>74.0</b>	<b>81.3</b>	<b>4.8</b>
<b>Minimum</b>	<b>20.7</b>	<b>26.8</b>	<b>0.6</b>	<b>24.5</b>	<b>52.3</b>	<b>1.0</b>

### Combustion Gas and VOC Emissions from Rotoman 2 Lower Wyndeham Heron, Maldon (16/10/12)



## 2.4.8 Uncertainty calculations

### UNCERTAINTY OF CARBON MONOXIDE BY HORIBA 1

Reading =	39.8	ppm
Span Gas Certified Value =	80.7	ppm +/-2%
Emission Limit Value	100	mg/Nm <sup>3</sup>

Parameter	Uncertainty criteria	Probability distribution	Divisor	U	U <sup>2</sup>
Repeatability (% of value)	1	Normal	1	0.3980	0.1584
Zero Drift/Lower limit of detection (ppm)	0.00	Rectangular	1.732	0.0000	0.0000
Span Drift (ppm)	0.40	Rectangular	1.732	0.2309	0.0533
Linearity (% of value)	1.01	Rectangular	1.732	0.2321	0.0539
Setting Gas Divider (% of value)	0.25	Normal	1	0.0995	0.0099
Interference (% of value)	2.9	Rectangular	1.732	0.6664	0.4441
Span Gas (% of span gasvalue)	1	Rectangular	1.732	0.4659	0.2171
				Sum U <sup>2</sup>	0.94
				<b>Combined Standard Uncertainty (ppm)</b>	0.97
				<b>Expanded Total Uncertainty (ppm) (95% Confidence)</b>	1.90
				<b>Expanded Total Uncertainty as a percentage of emission concentration(95% Confidence)</b>	4.8
				<b>Expanded Total Uncertainty (mg/Nm<sup>3</sup>) (95% Confidence)</b>	2.37
				<b>Expanded Total Uncertainty as a percentage of ELV (95% Confidence)</b>	2.4

### UNCERTAINTY OF OXIDES OF NITROGEN BY HORIBA 1

Reading =	30.3	ppm
Span Gas Certified Value =	49.1	ppm
Emission Limit Value	100	mg/Nm <sup>3</sup>

Parameter	Uncertainty criteria	Probability distribution	Divisor	U	U <sup>2</sup>
Repeatability (% of value)	1	Normal	1	0.3030	0.0918
Zero Drift/Lower limit of detection (ppm)	-0.10	Rectangular	1.732	-0.0577	0.0033
Span Drift (ppm)	0.00	Rectangular	1.732	0.0000	0.0000
Linearity (% of value)	1.41	Rectangular	1.732	0.2467	0.0608
Setting Gas Divider (% of value)	0.25	Normal	1	0.0758	0.0057
Interference (% of value)	1.2	Rectangular	1.732	0.2099	0.0441
Span Gas (% of span gasvalue)	1	Rectangular	1.732	0.2835	0.0804
				Sum U <sup>2</sup>	0.29
				<b>Combined Standard Uncertainty (ppm)</b>	0.53
				<b>Expanded Total Uncertainty (ppm) (95% Confidence)</b>	1.05
				<b>Expanded Total Uncertainty as a percentage of emission concentration(95% Confidence)</b>	3.5
				<b>Expanded Total Uncertainty (mg/Nm<sup>3</sup>) (95% Confidence)</b>	2.15
				<b>Expanded Total Uncertainty as a percentage of ELV (95% Confidence)</b>	2.2

### UNCERTAINTY OF VOC BY SIGNAL 1


Reading =	1.9	ppm as C <sub>3</sub> H <sub>8</sub>
Span Gas =	10.13	ppm +/-2%
Emission Limit Value	20	mg/Nm <sup>3</sup>

Parameter	Uncertainty criteria	Probability distribution	Divisor	U	U <sup>2</sup>
Repeatability (% of value)	1	Normal	1	0.0190	0.0004
Zero Drift/ Detection threshold	-0.40	Rectangular	1.732	-0.2309	0.0533
Span Drift (ppm)	-0.20	Rectangular	1.732	-0.1155	0.0133
Noise (ppm)	0.1	Rectangular	1.732	0.0577	0.0033
Linearity (% of value)	1.65	Rectangular	1.732	0.0181	0.0003
Setting Gas Divider (% of value)	0.25	Normal	1	0.0048	0.0000
Temperature Drift (% of value)	1	Rectangular	1.732	0.0110	0.0001
Span Gas (% of value)	1	Rectangular	1.732	0.0585	0.0034
				Sum U <sup>2</sup>	0.07
				<b>Combined Standard Uncertainty (ppm as C<sub>3</sub>H<sub>8</sub>)</b>	0.27
				<b>Expanded Total Uncertainty (ppm as C<sub>3</sub>H<sub>8</sub>) (95% Confidence)</b>	0.53
				<b>Expanded Total Uncertainty as a percentage of emission concentration(95% Confidence)</b>	28.1
				<b>Expanded Total Uncertainty (mg/Nm<sup>3</sup> as carbon) (95% Confidence)</b>	0.86
				<b>Expanded Total Uncertainty as a percentage of ELV (95% Confidence)</b>	4.3

---

## 2.5 Appendix 5: Rotoman 2 Upper Results and Calculations

### 2.5.1 Photograph of the sampling location and positions



## 2.5.2 Flow criteria measurements

Stack reference: **Rotoman 2 Upper** Date: **22/11/2012**  
 Duct dimensions: **50.0 cm**  
 Local barometric pressure: **1017 mbar**  
 Ambient Temperature: **23 °C** Pitot Coefficient = **0.822**  
 Micromanometer Calibration (K; mbar) = **289 1000**

Sample port (A)	Traverse point	Traverse position (D)	Distance (cm)	Velocity (m/s)		Temp (°C)
				Uncorr.	Corrd.	
Single	A1	0.05	2.5	9.2	10.9	333
	A2	0.15	7.5	9.1	10.7	333
	A3	0.25	12.5	5.5	6.5	333
	A4	0.35	17.5	5.4	6.4	333
	A5	0.45	22.5	5.8	6.8	333
	A6	0.55	27.5	6.0	7.1	333
	A7	0.65	32.5	5.5	6.5	333
	A8	0.75	37.5	4.9	5.8	333
	A9	0.85	42.5	4.9	5.8	333
	A10	0.95	47.5	5.2	6.1	333

<u>Velocity readings (m/s)</u>			
<b>Duct Mean m/s</b>		<b>7.3</b>	
Highest(a)	10.9	Lowest (b)	5.8

<u>Temperature readings</u>			
<b>Duct Mean °C</b>		<b>333</b>	
Duct Mean K 606			
Highest(a)	333.0	Lowest (b)	333.0

<u>Volumetric flow rate</u>			
Duct dimensions	50.0	(cm)	
Duct area	0.196	(m <sup>2</sup> )	
Mean duct velocity	7.3	(m/s)	
Mean duct temperature	333	(°C)	
Ambient pressure	1017	(mbar)	
<b>Vol. Flow rate at stack conditions</b>	<b>5131</b>	<b>(m<sup>3</sup>/hr)</b>	
<b>Vol flow rate corrd.</b>	<b>2320.6</b>	<b>(Nm<sup>3</sup>/hr)</b>	

### 2.5.3 Water vapour measurements

#### MOISTURE TEST FORM

**Client Name:** Wyndeham Heron  
**Job Number:** 5319

**Date:** 16/10/2012

**Stack Reference:** Rotoman 2 Upper

**Ambient Pressure (mbar):** 1005

**Stack Temperature (°C):** 341

**Gasmeter Coefficient:** 1.000

**Equipment used:** Pump 59

**Leak Check (l/min) Before:** 0.1

**After:** 0.1

**Gas Meter Temperature (°C):**

**Start:** 20

**End:** 30

**Mean:** 25

<b>Start Flow Reading (l/min)</b>	1.648	<b>Start Time</b>	15:10:00
<b>End Flow Reading (/minl)</b>	1.684	<b>End Time</b>	15:40:00
<b>Volume Sampled (l)</b>	50.0	<b>Total Time (min)</b>	30
<b>Corrected Volume Sampled (l)</b>	45.4		
<b>Sampling Rate (l/min)</b>	1.666		

	IMPINGER	
	1	2
<b>Start Weight of Impingers (g)</b>	93.2	91.2
<b>End Weight of Impingers (g)</b>	95.5	91.4
<b>Weight Gain (g)</b>	2.3	0.2

<b>Total Weight Gain (1+2+3+4) (g)</b>	2.5
<b>Total Weight Gain in litres (l)</b>	3.11

<b>Moisture Content of Gases (g/Nm<sup>3</sup>)</b>	55.0
<b>Moisture Content of Gases (%)</b>	6.41

### 2.5.4 Manual monitoring method - results – calculations

Not applicable.

### 2.5.5 Analysis results

Not applicable.

## 2.5.6 Instrumental gas analyser site calibration measurements

### ANALYSER CALIBRATIONS

#### Combustion Gas and VOC Emissions from Rotoman 2 (16/10/12)

Data entered by: MR

Horiba Analyser: Hor 1

Signal Analyser: Sig 1

Type of Gas	CO		NO		VOCs	
<b>Certified Calibration Values</b>	80.7	ppm +/-2%	49.1	ppm +/-2%	10.13	ppm +/-2%
<b>Response Time T90</b>	11.0	seconds	11.0	seconds	4.00	seconds
<b>Period</b>						
Span PreCal direct to analyser	79.9	ppm	49.0	ppm	-	ppm
Zero PreCal through sample line	1.0	ppm	0.1	ppm	0.0	ppm
Span PreCal through sample line	80.7	ppm	48.9	ppm	10.1	ppm
Zero PostCal through sample line	1.0	ppm	0.2	ppm	0.4	ppm
Span PostCal through sample line	80.3	ppm	48.9	ppm	10.3	ppm
Span Drift	0.5	%	0.0	%		
Zero Drift	0.0	%	-0.2	%		
Is data valid without adjustment	YES		YES			
Does data require adjustment	NO		NO			
Is data invalid	NO		NO			

## 2.5.7 Instrumental gas analyser results


### Gaseous Analysis using Horiba PG 250 & Signal 3030PM Analysers

Wyndeham Heron, Maldon

#### Combustion Gas and VOC Emissions from Rotoman 2 Upper (16/10/12)

	Carbon Monoxide CO (ppm)	Oxides of Nitrogen NOx (ppm)	VOCs (ppm)	Conversion from ppm to mg/Nm <sup>3</sup> WET		
				CO (mg/Nm <sup>3</sup> )	NOx (as NO <sub>2</sub> ) (mg/Nm <sup>3</sup> )	VOCs (mg/Nm <sup>3</sup> )
<b>Average</b>	<b>47.3</b>	<b>27.9</b>	<b>3.2</b>	<b>55.3</b>	<b>53.5</b>	<b>5.1</b>
<b>Maximum</b>	<b>77.0</b>	<b>43.2</b>	<b>10.1</b>	<b>90.1</b>	<b>83.1</b>	<b>16.2</b>
<b>Minimum</b>	<b>21.8</b>	<b>23.7</b>	<b>1.9</b>	<b>25.5</b>	<b>45.5</b>	<b>3.1</b>

### Combustion Gas and VOC Emissions from Rotoman 2 Upper Wyndeham Heron, Maldon (16/10/12)



## 2.5.8 Uncertainty calculations

### UNCERTAINTY OF CARBON MONOXIDE BY HORIBA 1

Reading =	47.3	ppm
Span Gas Certified Value =	80.7	ppm +/-2%
Emission Limit Value	100	mg/Nm <sup>3</sup>

Parameter	Uncertainty criteria	Probability distribution	Divisor	U	U <sup>2</sup>
Repeatability (% of value)	1	Normal	1	0.4730	0.2237
Zero Drift/Lower limit of detection (ppm)	0.00	Rectangular	1.732	0.0000	0.0000
Span Drift (ppm)	0.40	Rectangular	1.732	0.2309	0.0533
Linearity (% of value)	1.01	Rectangular	1.732	0.2758	0.0761
Setting Gas Divider (% of value)	0.25	Normal	1	0.1183	0.0140
Interference (% of value)	2.9	Rectangular	1.732	0.7920	0.6272
Span Gas (% of span gasvalue)	1	Rectangular	1.732	0.4659	0.2171
				Sum U <sup>2</sup>	1.21
				<b>Combined Standard Uncertainty (ppm)</b>	1.10
				<b>Expanded Total Uncertainty (ppm) (95% Confidence)</b>	2.16
				<b>Expanded Total Uncertainty as a percentage of emission concentration(95% Confidence)</b>	4.6
				<b>Expanded Total Uncertainty (mg/Nm<sup>3</sup>) (95% Confidence)</b>	2.70
				<b>Expanded Total Uncertainty as a percentage of ELV (95% Confidence)</b>	2.7

### UNCERTAINTY OF OXIDES OF NITROGEN BY HORIBA 1

Reading =	27.9	ppm
Span Gas Certified Value =	49.1	ppm
Emission Limit Value	100	mg/Nm <sup>3</sup>

Parameter	Uncertainty criteria	Probability distribution	Divisor	U	U <sup>2</sup>
Repeatability (% of value)	1	Normal	1	0.2790	0.0778
Zero Drift/Lower limit of detection (ppm)	-0.10	Rectangular	1.732	-0.0577	0.0033
Span Drift (ppm)	0.00	Rectangular	1.732	0.0000	0.0000
Linearity (% of value)	1.41	Rectangular	1.732	0.2271	0.0516
Setting Gas Divider (% of value)	0.25	Normal	1	0.0698	0.0049
Interference (% of value)	1.2	Rectangular	1.732	0.1933	0.0374
Span Gas (% of span gasvalue)	1	Rectangular	1.732	0.2835	0.0804
				Sum U <sup>2</sup>	0.26
				<b>Combined Standard Uncertainty (ppm)</b>	0.51
				<b>Expanded Total Uncertainty (ppm) (95% Confidence)</b>	0.99
				<b>Expanded Total Uncertainty as a percentage of emission concentration(95% Confidence)</b>	3.5
				<b>Expanded Total Uncertainty (mg/Nm<sup>3</sup>) (95% Confidence)</b>	2.03
				<b>Expanded Total Uncertainty as a percentage of ELV (95% Confidence)</b>	2.0

### UNCERTAINTY OF VOC BY SIGNAL 1

Reading =	3.2	ppm as C <sub>3</sub> H <sub>8</sub>
Span Gas=	10.13	ppm +/-2%
Emission Limit Value	20	mg/Nm <sup>3</sup>

Parameter	Uncertainty criteria	Probability distribution	Divisor	U	U <sup>2</sup>
Repeatability (% of value)	1	Normal	1	0.0320	0.0010
Zero Drift/ Detection threshold	-0.40	Rectangular	1.732	-0.2309	0.0533
Span Drift (ppm)	-0.20	Rectangular	1.732	-0.1155	0.0133
Noise (ppm)	0.1	Rectangular	1.732	0.0577	0.0033
Linearity (% of value)	1.65	Rectangular	1.732	0.0305	0.0009
Setting Gas Divider (% of value)	0.25	Normal	1	0.0080	0.0001
Temperature Drift (% of value)	1	Rectangular	1.732	0.0185	0.0003
Span Gas (% of value)	1	Rectangular	1.732	0.0585	0.0034
				Sum U <sup>2</sup>	0.08
				<b>Combined Standard Uncertainty (ppm as C<sub>3</sub>H<sub>8</sub>)</b>	0.28
				<b>Expanded Total Uncertainty (ppm as C<sub>3</sub>H<sub>8</sub>) (95% Confidence)</b>	0.54
				<b>Expanded Total Uncertainty as a percentage of emission concentration(95% Confidence)</b>	16.9
				<b>Expanded Total Uncertainty (mg/Nm<sup>3</sup> as carbon) (95% Confidence)</b>	0.87
				<b>Expanded Total Uncertainty as a percentage of ELV (95% Confidence)</b>	4.3

## 2.6 Appendix 6: Rotoman 3 Lower Results and Calculations

### 2.6.1 Photograph of the sampling location and positions



## 2.6.2 Flow criteria measurements

Stack reference: **Rotoman 3 Lower** Date: **22/11/2012**  
 Duct dimensions: **50.0 cm**  
 Local barometric pressure: **1017 mbar**  
 Ambient Temperature: **23 °C** Pitot Coefficient = **0.822**  
 Micromanometer Calibration (K; mbar) = **289 1000**

Sample port (A)	Traverse point	Traverse position (D)	Distance (cm)	Velocity (m/s)		Temp (°C)
				Uncorr.	Corrd.	
Single	A1	0.05	2.5	10.9	13.1	354
	A2	0.15	7.5	11.4	13.7	354
	A3	0.25	12.5	11.2	13.4	354
	A4	0.35	17.5	11.0	13.2	354
	A5	0.45	22.5	10.9	13.1	354
	A6	0.55	27.5	10.8	13.0	354
	A7	0.65	32.5	10.9	13.1	354
	A8	0.75	37.5	10.4	12.5	354
	A9	0.85	42.5	10.2	12.2	354
	A10	0.95	47.5	9.9	11.9	354

<u>Velocity readings (m/s)</u>			
<b>Duct Mean m/s</b>		<b>12.9</b>	
Highest(a)	13.7	Lowest (b)	11.9

<u>Temperature readings</u>			
<b>Duct Mean °C</b>		<b>354</b>	
Duct Mean K 627			
Highest(a)	354.0	Lowest (b)	354.0

<u>Volumetric flow rate</u>			
Duct dimensions	50.0	(cm)	
Duct area	0.196	(m <sup>2</sup> )	
Mean duct velocity	12.9	(m/s)	
Mean duct temperature	354	(°C)	
Ambient pressure	1017	(mbar)	
<b>Vol. Flow rate at stack conditions</b>	<b>9131</b>	<b>(m<sup>3</sup>/hr)</b>	
<b>Vol flow rate corrd.</b>	<b>3991.6</b>	<b>(Nm<sup>3</sup>/hr)</b>	

### 2.6.3 Water vapour measurements

#### MOISTURE TEST FORM

**Client Name:** Wyndeham Heron  
**Job Number:** 5319

**Date:** 16/10/2012

**Stack Reference:** Rotoman 3 Lower

**Ambient Pressure (mbar):** 1005

**Stack Temperature (°C):** 360

**Gasmeter Coefficient:** 1.000

**Equipment used:** Pump 59

**Leak Check (l/min) Before:** 0.1

**After:** 0.1

**Gas Meter Temperature (°C):**

**Start:** 20

**End:** 30

**Mean:** 25

<b>Start Flow Reading (l/min)</b>	1.65	<b>Start Time</b>	11:39:00
<b>End Flow Reading (/minl)</b>	1.64	<b>End Time</b>	12:09:00
<b>Volume Sampled (l)</b>	49.4	<b>Total Time (min)</b>	30
<b>Corrected Volume Sampled (l)</b>	44.9		
<b>Sampling Rate (l/min)</b>	1.645		

	IMPINGER	
	1	2
<b>Start Weight of Impingers (g)</b>	91.8	92.7
<b>End Weight of Impingers (g)</b>	94.6	92.7
<b>Weight Gain (g)</b>	2.8	0.0

<b>Total Weight Gain (1+2+3+4) (g)</b>	2.8
<b>Total Weight Gain in litres (l)</b>	3.49

<b>Moisture Content of Gases (g/Nm<sup>3</sup>)</b>	62.4
<b>Moisture Content of Gases (%)</b>	7.21

### 2.6.4 Manual monitoring method - results – calculations

Not applicable.

### 2.6.5 Analysis results

Not applicable.

## 2.6.6 Instrumental gas analyser site calibration measurements

### ANALYSER CALIBRATIONS Combustion Gas and VOC Emissions from Rotoman 3 (16/10/12)

Data entered by: MR  
 Horiba Analyser: Hor 2  
 Signal Analyser: Sig 3


Type of Gas	CO		NO		VOCs	
<b>Certified Calibration Values</b>	80.7	ppm +/-2%	49.1	ppm +/-2%	10.13	ppm +/-2%
<b>Response Time T90</b>	15.0	seconds	15.0	seconds	4.00	seconds
<b>Period</b>						
Span PreCal direct to analyser	81.1	ppm	49.3	ppm	-	ppm
Zero PreCal through sample line	-0.1	ppm	0.1	ppm	0.0	ppm
Span PreCal through sample line	81.0	ppm	48.5	ppm	10.1	ppm
Zero PostCal through sample line	0.3	ppm	0.0	ppm	-0.5	ppm
Span PostCal through sample line	80.8	ppm	48.4	ppm	9.8	ppm
Span Drift	0.2	%	0.2	%		
Zero Drift	-0.5	%	0.2	%		
Is data valid without adjustment	YES		YES			
Does data require adjustment	NO		NO			
Is data invalid	NO		NO			

## 2.6.7 Instrumental gas analyser results

### Gaseous Analysis using Horiba PG 250 & Signal 3030PM Analysers Wyndeham Heron, Maldon Combustion Gas and VOC Emissions from Rotoman 3 Lower (16/10/12)

	Carbon Monoxide CO (ppm)	Oxides of Nitrogen NOx (ppm)	VOCs (ppm)	Conversion from ppm to mg/Nm <sup>3</sup> WET		
				CO (mg/Nm <sup>3</sup> )	NOx (as NO <sub>2</sub> ) (mg/Nm <sup>3</sup> )	VOCs (mg/Nm <sup>3</sup> )
<b>Average</b>	<b>51.1</b>	<b>27.2</b>	<b>1.2</b>	<b>59.3</b>	<b>51.7</b>	<b>1.9</b>
<b>Maximum</b>	<b>96.6</b>	<b>31.6</b>	<b>2.4</b>	<b>112.0</b>	<b>60.2</b>	<b>3.9</b>
<b>Minimum</b>	<b>30.1</b>	<b>25.4</b>	<b>0.6</b>	<b>34.9</b>	<b>48.4</b>	<b>0.9</b>

### Combustion Gas and VOC Emissions from Rotoman 3 Lower Wyndeham Heron, Maldon (16/10/12)



## 2.6.8 Uncertainty calculations

### UNCERTAINTY OF CARBON MONOXIDE BY HORIBA 2

Reading =	51.1	ppm
Span Gas Certified Value =	80.7	ppm +/-2%
Emission Limit Value	100	mg/Nm <sup>3</sup>

Parameter	Uncertainty criteria	Probability distribution	Divisor	U	U <sup>2</sup>
Repeatability (% of value)	1	Normal	1	0.5110	0.2611
Zero Drift/Lower limit of detection (ppm)	-0.40	Rectangular	1.732	-0.2309	0.0533
Span Drift (ppm)	0.20	Rectangular	1.732	0.1155	0.0133
Linearity (% of value)	0.54	Rectangular	1.732	0.1593	0.0254
Setting Gas Divider (% of value)	0.25	Normal	1	0.1278	0.0163
Interference (% of value)	2.9	Rectangular	1.732	0.8556	0.7321
Span Gas (% of span gasvalue)	1	Rectangular	1.732	0.4659	0.2171
				Sum U <sup>2</sup>	1.32
				<b>Combined Standard Uncertainty (ppm)</b>	1.15
				<b>Expanded Total Uncertainty (ppm) (95% Confidence)</b>	2.25
				<b>Expanded Total Uncertainty as a percentage of emission concentration(95% Confidence)</b>	4.4
				<b>Expanded Total Uncertainty (mg/Nm<sup>3</sup>) (95% Confidence)</b>	2.81
				<b>Expanded Total Uncertainty as a percentage of ELV (95% Confidence)</b>	2.8

### UNCERTAINTY OF OXIDES OF NITROGEN BY HORIBA 2

Reading =	27.2	ppm
Span Gas Certified Value =	49.1	ppm
Emission Limit Value	100	mg/Nm <sup>3</sup>

Parameter	Uncertainty criteria	Probability distribution	Divisor	U	U <sup>2</sup>
Repeatability (% of value)	1	Normal	1	0.2720	0.0740
Zero Drift/Lower limit of detection (ppm)	0.10	Rectangular	1.732	0.0577	0.0033
Span Drift (ppm)	0.10	Rectangular	1.732	0.0577	0.0033
Linearity (% of value)	1.16	Rectangular	1.732	0.1822	0.0332
Setting Gas Divider (% of value)	0.25	Normal	1	0.0680	0.0046
Interference (% of value)	1.2	Rectangular	1.732	0.1885	0.0355
Span Gas (% of span gasvalue)	1	Rectangular	1.732	0.2835	0.0804
				Sum U <sup>2</sup>	0.23
				<b>Combined Standard Uncertainty (ppm)</b>	0.48
				<b>Expanded Total Uncertainty (ppm) (95% Confidence)</b>	0.95
				<b>Expanded Total Uncertainty as a percentage of emission concentration(95% Confidence)</b>	3.5
				<b>Expanded Total Uncertainty (mg/Nm<sup>3</sup>) (95% Confidence)</b>	1.95
				<b>Expanded Total Uncertainty as a percentage of ELV (95% Confidence)</b>	1.9

### UNCERTAINTY OF VOC BY SIGNAL3

Reading =	1.2	ppm as C <sub>3</sub> H <sub>8</sub>
Span Gas =	10.13	ppm +/-2%
Emission Limit Value	20	mg/Nm <sup>3</sup>

Parameter	Uncertainty criteria	Probability distribution	Divisor	U	U <sup>2</sup>
Repeatability (% of value)	1	Normal	1	0.0120	0.0001
Zero Drift/ Detection threshold	0.50	Rectangular	1.732	0.2887	0.0833
Span Drift (ppm)	0.30	Rectangular	1.732	0.1732	0.0300
Noise (ppm)	0.1	Rectangular	1.732	0.0577	0.0033
Linearity (% of value)	0.85	Rectangular	1.732	0.0059	0.0000
Setting Gas Divider (% of value)	0.25	Normal	1	0.0030	0.0000
Temperature Drift (% of value)	1	Rectangular	1.732	0.0069	0.0000
Span Gas (% of value)	1	Rectangular	1.732	0.0585	0.0034
				Sum U <sup>2</sup>	0.12
				<b>Combined Standard Uncertainty (ppm as C<sub>3</sub>H<sub>8</sub>)</b>	0.35
				<b>Expanded Total Uncertainty (ppm as C<sub>3</sub>H<sub>8</sub>) (95% Confidence)</b>	0.68
				<b>Expanded Total Uncertainty as a percentage of emission concentration(95% Confidence)</b>	56.7
				<b>Expanded Total Uncertainty (mg/Nm<sup>3</sup> as carbon) (95% Confidence)</b>	1.09
				<b>Expanded Total Uncertainty as a percentage of ELV (95% Confidence)</b>	5.5

---

## 2.7 Appendix 7: Rotoman 3 Upper Results and Calculations

### 2.7.1 Photograph of the sampling location and positions



## 2.7.2 Flow criteria measurements

Stack reference: **Rotoman 3 Upper** Date: **22/11/2012**  
 Duct dimensions: **50.0 cm**  
 Local barometric pressure: **1017 mbar**  
 Ambient Temperature: **23 °C** Pitot Coefficient = **0.822**  
 Micromanometer Calibration (K; mbar) = **289 1000**

Sample port (A)	Traverse point	Traverse position (D)	Distance (cm)	Velocity (m/s)		Temp (°C)
				Uncorr.	Corrd.	
Single	A1	0.05	2.5	13.6	16.4	358
	A2	0.15	7.5	13.0	15.7	358
	A3	0.25	12.5	12.6	15.2	358
	A4	0.35	17.5	9.9	11.9	358
	A5	0.45	22.5	8.9	10.7	358
	A6	0.55	27.5	9.0	10.8	358
	A7	0.65	32.5	8.8	10.6	358
	A8	0.75	37.5	9.4	11.3	358
	A9	0.85	42.5	9.3	11.2	358
	A10	0.95	47.5	9.7	11.7	358

<u>Velocity readings (m/s)</u>			
<b>Duct Mean m/s</b>		<b>12.6</b>	
Highest(a)	16.4	Lowest (b)	10.6

<u>Temperature readings</u>			
<b>Duct Mean °C</b>		<b>358</b>	
Duct Mean K	631		
Highest(a)	358.0	Lowest (b)	358.0

<u>Volumetric flow rate</u>			
Duct dimensions	50.0	(cm)	
Duct area	0.196	(m <sup>2</sup> )	
Mean duct velocity	12.6	(m/s)	
Mean duct temperature	358	(°C)	
Ambient pressure	1017	(mbar)	
<b>Vol. Flow rate at stack conditions</b>	<b>8871</b>	<b>(m<sup>3</sup>/hr)</b>	
<b>Vol flow rate corrd.</b>	<b>3853.2</b>	<b>(Nm<sup>3</sup>/hr)</b>	

### 2.7.3 Water vapour measurements

#### MOISTURE TEST FORM

**Client Name:** Wyndeham Heron  
**Job Number:** 5319

**Date:** 16/10/2012

**Stack Reference:** Rotoman 3 Upper

**Ambient Pressure (mbar):** 1005

**Gas Meter Temperature (°C):**

**Stack Temperature (°C):** 365

**Start:** 20

**Gasmeter Coefficient:** 1.000

**End:** 30

**Equipment used:** Pump 59

**Mean:** 25

**Leak Check (l/min) Before:** 0.1

**After:** 0.1

<b>Start Flow Reading (l/min)</b>	1.594	<b>Start Time</b>	12:24:00
<b>End Flow Reading (/minl)</b>	1.606	<b>End Time</b>	12:54:00
<b>Volume Sampled (l)</b>	48.0	<b>Total Time (min)</b>	30
<b>Corrected Volume Sampled (l)</b>	43.6		
<b>Sampling Rate (l/min)</b>	1.600		

	IMPINGER	
	1	2
<b>Start Weight of Impingers (g)</b>	91.6	92.7
<b>End Weight of Impingers (g)</b>	93.8	93.2
<b>Weight Gain (g)</b>	2.2	0.5

<b>Total Weight Gain (1+2+3+4) (g)</b>	2.7
<b>Total Weight Gain in litres (l)</b>	3.36

<b>Moisture Content of Gases (g/Nm<sup>3</sup>)</b>	61.9
<b>Moisture Content of Gases (%)</b>	7.16

### 2.7.4 Manual monitoring method - results – calculations

Not applicable.

### 2.7.5 Analysis results

Not applicable.

## 2.7.6 Instrumental gas analyser site calibration measurements

### ANALYSER CALIBRATIONS

#### Combustion Gas and VOC Emissions from Rotoman 3 (16/10/12)

Data entered by: MR

Horiba Analyser: Hor 2

Signal Analyser: Sig 3

Type of Gas	CO		NO		VOCs	
<b>Certified Calibration Values</b>	80.7	ppm +/-2%	49.1	ppm +/-2%	10.13	ppm +/-2%
<b>Response Time T90</b>	15.0	seconds	15.0	seconds	4.00	seconds
<b>Period</b>						
Span PreCal direct to analyser	81.1	ppm	49.3	ppm	-	ppm
Zero PreCal through sample line	-0.1	ppm	0.1	ppm	0.0	ppm
Span PreCal through sample line	81.0	ppm	48.5	ppm	10.1	ppm
Zero PostCal through sample line	0.3	ppm	0.0	ppm	-0.5	ppm
Span PostCal through sample line	80.8	ppm	48.4	ppm	9.8	ppm
Span Drift	0.2	%	0.2	%		
Zero Drift	-0.5	%	0.2	%		
Is data valid without adjustment	YES		YES			
Does data require adjustment	NO		NO			
Is data invalid	NO		NO			

## 2.7.7 Instrumental gas analyser results


### Gaseous Analysis using Horiba PG 250 & Signal 3030PM Analysers

Wyndeham Heron, Maldon

#### Combustion Gas and VOC Emissions from Rotoman 3 Upper (16/10/12)

	Carbon Monoxide CO (ppm)	Oxides of Nitrogen NOx (ppm)	VOCs (ppm)	Conversion from ppm to mg/Nm <sup>3</sup> WET		
				CO (mg/Nm <sup>3</sup> )	NOx (as NO <sub>2</sub> ) (mg/Nm <sup>3</sup> )	VOCs (mg/Nm <sup>3</sup> )
<b>Average</b>	<b>52.1</b>	<b>27.9</b>	<b>1.2</b>	<b>60.5</b>	<b>53.2</b>	<b>1.9</b>
<b>Maximum</b>	<b>91.0</b>	<b>31.6</b>	<b>1.7</b>	<b>105.6</b>	<b>60.3</b>	<b>2.8</b>
<b>Minimum</b>	<b>29.2</b>	<b>26.2</b>	<b>0.7</b>	<b>33.9</b>	<b>49.9</b>	<b>1.1</b>

### Combustion Gas and VOC Emissions from Rotoman 3 Upper Wyndeham Heron, Maldon (16/10/12)



## 2.7.8 Uncertainty calculations

### UNCERTAINTY OF CARBON MONOXIDE BY HORIBA 2

Reading =	52.1	ppm
Span Gas Certified Value =	80.7	ppm +/-2%
Emission Limit Value	100	mg/Nm <sup>3</sup>

Parameter	Uncertainty criteria	Probability distribution	Divisor	U	U <sup>2</sup>
Repeatability (% of value)	1	Normal	1	0.5210	0.2714
Zero Drift/Lower limit of detection (ppm)	-0.40	Rectangular	1.732	-0.2309	0.0533
Span Drift (ppm)	0.20	Rectangular	1.732	0.1155	0.0133
Linearity (% of value)	0.54	Rectangular	1.732	0.1624	0.0264
Setting Gas Divider (% of value)	0.25	Normal	1	0.1303	0.0170
Interference (% of value)	2.9	Rectangular	1.732	0.8723	0.7610
Span Gas (% of span gasvalue)	1	Rectangular	1.732	0.4659	0.2171
				Sum U <sup>2</sup>	1.36
				<b>Combined Standard Uncertainty (ppm)</b>	1.17
				<b>Expanded Total Uncertainty (ppm) (95% Confidence)</b>	2.29
				<b>Expanded Total Uncertainty as a percentage of emission concentration(95% Confidence)</b>	4.4
				<b>Expanded Total Uncertainty (mg/Nm<sup>3</sup>) (95% Confidence)</b>	2.86
				<b>Expanded Total Uncertainty as a percentage of ELV (95% Confidence)</b>	2.9

### UNCERTAINTY OF OXIDES OF NITROGEN BY HORIBA 2

Reading =	27.9	ppm
Span Gas Certified Value =	49.1	ppm
Emission Limit Value	100	mg/Nm <sup>3</sup>

Parameter	Uncertainty criteria	Probability distribution	Divisor	U	U <sup>2</sup>
Repeatability (% of value)	1	Normal	1	0.2790	0.0778
Zero Drift/Lower limit of detection (ppm)	0.10	Rectangular	1.732	0.0577	0.0033
Span Drift (ppm)	0.10	Rectangular	1.732	0.0577	0.0033
Linearity (% of value)	1.16	Rectangular	1.732	0.1869	0.0349
Setting Gas Divider (% of value)	0.25	Normal	1	0.0698	0.0049
Interference (% of value)	1.2	Rectangular	1.732	0.1933	0.0374
Span Gas (% of span gasvalue)	1	Rectangular	1.732	0.2835	0.0804
				Sum U <sup>2</sup>	0.24
				<b>Combined Standard Uncertainty (ppm)</b>	0.49
				<b>Expanded Total Uncertainty (ppm) (95% Confidence)</b>	0.96
				<b>Expanded Total Uncertainty as a percentage of emission concentration(95% Confidence)</b>	3.5
				<b>Expanded Total Uncertainty (mg/Nm<sup>3</sup>) (95% Confidence)</b>	1.98
				<b>Expanded Total Uncertainty as a percentage of ELV (95% Confidence)</b>	2.0

### UNCERTAINTY OF VOC BY SIGNAL3

Reading =	1.2	ppm as C <sub>3</sub> H <sub>8</sub>
Span Gas=	10.13	ppm+/-2%
Emission Limit Value	20	mg/Nm <sup>3</sup>

Parameter	Uncertainty criteria	Probability distribution	Divisor	U	U <sup>2</sup>
Repeatability (% of value)	1	Normal	1	0.0120	0.0001
Zero Drift/ Detection threshold	0.50	Rectangular	1.732	0.2887	0.0833
Span Drift (ppm)	0.30	Rectangular	1.732	0.1732	0.0300
Noise (ppm)	0.1	Rectangular	1.732	0.0577	0.0033
Linearity (% of value)	0.85	Rectangular	1.732	0.0059	0.0000
Setting Gas Divider (% of value)	0.25	Normal	1	0.0030	0.0000
Temperature Drift (% of value)	1	Rectangular	1.732	0.0069	0.0000
Span Gas (% of value)	1	Rectangular	1.732	0.0585	0.0034
				Sum U <sup>2</sup>	0.12
				<b>Combined Standard Uncertainty (ppm as C<sub>3</sub>H<sub>8</sub>)</b>	0.35
				<b>Expanded Total Uncertainty (ppm as C<sub>3</sub>H<sub>8</sub>) (95% Confidence)</b>	0.68
				<b>Expanded Total Uncertainty as a percentage of emission concentration(95% Confidence)</b>	56.7
				<b>Expanded Total Uncertainty (mg/Nm<sup>3</sup> as carbon) (95% Confidence)</b>	1.09
				<b>Expanded Total Uncertainty as a percentage of ELV (95% Confidence)</b>	5.5

---

## 2.8 Appendix 8: Lithoman 1 Results and Calculations

### 2.8.1 Photograph of the sampling location and positions



## 2.8.2 Flow criteria measurements

Stack reference: **Lithoman 1** Date: **22/11/2012**  
 Duct dimensions: **60.0 cm**  
 Local barometric pressure: **1017 mbar**  
 Ambient Temperature: **23 °C** Pitot Coefficient = **0.997**  
 Micromanometer Calibration (K; mbar) = **289 1000**

Sample port (A)	Traverse point	Traverse position (D)	Distance (cm)	Velocity (m/s)		Temp (°C)
				Uncorr.	Corrd.	
Single	A1	0.05	3.0	10.1	14.8	362
	A2	0.15	9.0	10.5	15.4	362
	A3	0.25	15.0	11.7	17.1	362
	A4	0.35	21.0	13.3	19.5	362
	A5	0.45	27.0	13.1	19.2	362
	A6	0.55	33.0	10.3	15.1	362
	A7	0.65	39.0	7.6	11.1	362
	A8	0.75	45.0	2.8	4.1	362
	A9	0.85	51.0	0.0	0.0	362
	A10	0.95	57.0	12.4	18.2	362

<u>Velocity readings (m/s)</u>			
<b>Duct Mean m/s</b>		<b>13.5</b>	
Highest(a)	19.5	Lowest (b)	0.0

<u>Temperature readings</u>			
<b>Duct Mean °C</b>		<b>362</b>	
Duct Mean K 635			
Highest(a)	362.0	Lowest (b)	362.0

<u>Volumetric flow rate</u>			
Duct dimensions	60.0	(cm)	
Duct area	0.283	(m <sup>2</sup> )	
Mean duct velocity	13.5	(m/s)	
Mean duct temperature	362	(°C)	
Ambient pressure	1017	(mbar)	
<b>Vol. Flow rate at stack conditions</b>	<b>13693</b>	<b>(m<sup>3</sup>/hr)</b>	
<b>Vol flow rate corrd.</b>	<b>5910.3</b>	<b>(Nm<sup>3</sup>/hr)</b>	

### 2.8.3 Water vapour measurements

#### MOISTURE TEST FORM

**Client Name:** Wyndeham Heron  
**Job Number:** 5319

**Date:** 15/10/2012

**Stack Reference:** Lithoman 1

**Ambient Pressure (mbar):** 1006  
**Stack Temperature (°C):** 270  
**Gasmeter Coefficient:** 1.000  
**Equipment used:** Pump 59  
**Leak Check (l/min) Before:** 0.1  
**After:** 0.1

**Gas Meter Temperature (°C):**  
**Start:** 20  
**End:** 30  
**Mean:** 25

<b>Start Flow Reading (l/min)</b>	1.561	<b>Start Time</b>	18:20:00
<b>End Flow Reading (l/min)</b>	1.609	<b>End Time</b>	18:40:00
<b>Volume Sampled (l)</b>	31.7	<b>Total Time (min)</b>	20
<b>Corrected Volume Sampled (l)</b>	28.8		
<b>Sampling Rate (l/min)</b>	1.585		

	IMPINGER	
	1	2
<b>Start Weight of Impingers (g)</b>	90.0	91.1
<b>End Weight of Impingers (g)</b>	92.3	91
<b>Weight Gain (g)</b>	2.3	-0.1

<b>Total Weight Gain (1+2+3+4) (g)</b>	2.2
<b>Total Weight Gain in litres (l)</b>	2.74

<b>Moisture Content of Gases (g/Nm<sup>3</sup>)</b>	76.3
<b>Moisture Content of Gases (%)</b>	8.67

### 2.8.4 Manual monitoring method - results – calculations

Not applicable.

### 2.8.5 Analysis results

Not applicable.

## 2.8.6 Instrumental gas analyser site calibration measurements

### ANALYSER CALIBRATIONS

#### Combustion Gas and VOC Emissions from Lithoman 1 (15/10/12)

Data entered by: MR

Horiba Analyser: Hor 2

Signal Analyser: Sig 3

Type of Gas	CO		NO		VOCs	
<b>Certified Calibration Values</b>	80.7	ppm +/-2%	49.1	ppm +/-2%	10.10	ppm +/-2%
<b>Response Time T90</b>	11.0	seconds	11.0	seconds	4.00	seconds
<b>Period</b>						
Span PreCal direct to analyser	81.2	ppm	49.2	ppm	-	ppm
Zero PreCal through sample line	0.1	ppm	0.1	ppm	0.3	ppm
Span PreCal through sample line	80.8	ppm	48.7	ppm	10.2	ppm
Zero PostCal through sample line	0.5	ppm	0.1	ppm	0.0	ppm
Span PostCal through sample line	81.8	ppm	48.4	ppm	9.7	ppm
Span Drift	-1.2	%	0.6	%		
Zero Drift	-0.5	%	0.0	%		
Is data valid without adjustment	YES		YES			
Does data require adjustment	NO		NO			
Is data invalid	NO		NO			

## 2.8.7 Instrumental gas analyser results

### Gaseous Analysis using Horiba PG 250 & Signal 3030PM Analysers

Wyndeham Heron, Maldon

#### Combustion Gas and VOC Emissions from Lithoman 1 (15/10/12)

	Carbon Monoxide CO (ppm)	Oxides of Nitrogen NOx (ppm)	VOCs (ppm)	Conversion from ppm to mg/Nm <sup>3</sup> WET		
				CO (mg/Nm <sup>3</sup> )	NOx (as NO <sub>2</sub> ) (mg/Nm <sup>3</sup> )	VOCs (mg/Nm <sup>3</sup> )
<b>Average</b>	<b>56.8</b>	<b>27.0</b>	<b>0.0</b>	<b>64.8</b>	<b>50.5</b>	<b>0.0</b>
<b>Maximum</b>	<b>77.4</b>	<b>30.0</b>	<b>0.0</b>	<b>88.4</b>	<b>56.2</b>	<b>0.0</b>
<b>Minimum</b>	<b>39.4</b>	<b>25.9</b>	<b>0.0</b>	<b>45.0</b>	<b>48.4</b>	<b>0.0</b>

### Combustion Gas and VOC Emissions from Lithoman 1 Wyndeham Heron, Maldon (15/10/12)



## 2.8.8 Uncertainty calculations

### UNCERTAINTY OF CARBON MONOXIDE BY HORIBA 2

Reading =	56.8	ppm
Span Gas Certified Value =	80.7	ppm +/-2%
Emission Limit Value	100	mg/Nm <sup>3</sup>

Parameter	Uncertainty criteria	Probability distribution	Divisor	U	U <sup>2</sup>
Repeatability (% of value)	1	Normal	1	0.5680	0.3226
Zero Drift/Lower limit of detection (ppm)	-0.40	Rectangular	1.732	-0.2309	0.0533
Span Drift (ppm)	-1.00	Rectangular	1.732	-0.5774	0.3334
Linearity (% of value)	0.54	Rectangular	1.732	0.1771	0.0314
Setting Gas Divider (% of value)	0.25	Normal	1	0.1420	0.0202
Interference (% of value)	2.9	Rectangular	1.732	0.9510	0.9045
Span Gas (% of span gasvalue)	1	Rectangular	1.732	0.4659	0.2171
				Sum U <sup>2</sup>	1.88
				<b>Combined Standard Uncertainty (ppm)</b>	1.37
				<b>Expanded Total Uncertainty (ppm) (95% Confidence)</b>	2.69
				<b>Expanded Total Uncertainty as a percentage of emission concentration(95% Confidence)</b>	4.7
				<b>Expanded Total Uncertainty (mg/Nm<sup>3</sup>) (95% Confidence)</b>	3.36
				<b>Expanded Total Uncertainty as a percentage of ELV (95% Confidence)</b>	3.4

### UNCERTAINTY OF OXIDES OF NITROGEN BY HORIBA 2

Reading =	27.0	ppm
Span Gas Certified Value =	49.1	ppm
Emission Limit Value	100	mg/Nm <sup>3</sup>

Parameter	Uncertainty criteria	Probability distribution	Divisor	U	U <sup>2</sup>
Repeatability (% of value)	1	Normal	1	0.2700	0.0729
Zero Drift/Lower limit of detection (ppm)	0.00	Rectangular	1.732	0.0000	0.0000
Span Drift (ppm)	0.30	Rectangular	1.732	0.1732	0.0300
Linearity (% of value)	1.16	Rectangular	1.732	0.1808	0.0327
Setting Gas Divider (% of value)	0.25	Normal	1	0.0675	0.0046
Interference (% of value)	1.2	Rectangular	1.732	0.1871	0.0350
Span Gas (% of span gasvalue)	1	Rectangular	1.732	0.2835	0.0804
				Sum U <sup>2</sup>	0.26
				<b>Combined Standard Uncertainty (ppm)</b>	0.51
				<b>Expanded Total Uncertainty (ppm) (95% Confidence)</b>	0.99
				<b>Expanded Total Uncertainty as a percentage of emission concentration(95% Confidence)</b>	3.7
				<b>Expanded Total Uncertainty (mg/Nm<sup>3</sup>) (95% Confidence)</b>	2.03
				<b>Expanded Total Uncertainty as a percentage of ELV (95% Confidence)</b>	2.0

### UNCERTAINTY OF VOC BY SIGNAL3

Reading =	0.1	ppm as C3H8
Span Gas=	10.13	ppm +/-2%
Emission Limit Value	20	mg/Nm <sup>3</sup>

Parameter	Uncertainty criteria	Probability distribution	Divisor	U	U <sup>2</sup>
Repeatability (% of value)	1	Normal	1	0.0010	0.0000
Zero Drift/ Detection threshold	0.30	Rectangular	1.732	0.1732	0.0300
Span Drift (ppm)	0.50	Rectangular	1.732	0.2887	0.0833
Noise (ppm)	0.1	Rectangular	1.732	0.0577	0.0033
Linearity (% of value)	0.85	Rectangular	1.732	0.0005	0.0000
Setting Gas Divider (% of value)	0.25	Normal	1	0.0003	0.0000
Temperature Drift (% of value)	1	Rectangular	1.732	0.0006	0.0000
Span Gas (% of value)	1	Rectangular	1.732	0.0585	0.0034
				Sum U <sup>2</sup>	0.12
				<b>Combined Standard Uncertainty (ppm as C3H8)</b>	0.35
				<b>Expanded Total Uncertainty (ppm as C3H8] (95% Confidence)</b>	0.68
				<b>Expanded Total Uncertainty as a percentage of emission concentration(95% Confidence)</b>	679.2
				<b>Expanded Total Uncertainty (mg/Nm<sup>3</sup> as carbon) (95% Confidence)</b>	1.09
				<b>Expanded Total Uncertainty as a percentage of ELV (95% Confidence)</b>	5.5

---

## 2.9 Appendix 9: Compactor Results and Calculations

### 2.9.1 Photograph of the sampling location and positions



### 2.9.2 Flow criteria measurements

Not applicable.

### 2.9.3 Water vapour measurements

Not applicable.

### 2.9.4 Analysis results

Not applicable.

### 2.9.5 Instrumental gas analyser site calibration measurements

Not applicable.

### 2.9.6 Instrumental gas analyser results

Not applicable.

## 2.9.7 Manual monitoring method - results – calculations

**Wyndeham Heron**  
**PARTICULATE MATTER EMISSIONS TO ATMOSPHERE DATA (MDHS 14 METHOD)**

Site: <b>Wyndeham Heron</b>		Duct: <b>Compactor</b>															
Atmospheric Press: 1005 mbar																	
PARTICULATE MONITORING (MDHS-14)																	
Duct Reference	Pump No.	Filter No.	Flow Start (l/min)	Checks Finish (l/min)	Average Flow (l/min)	Time ON (hr:m:s)	Time OFF (hr:m:s)	Elapsed Time (hr:m:s)	Elapsed Time (min)	Air Volume Sampled (m³)	Filter Masses			Concn. Partic. Matter (mg/m³)	Corr. Part.Matt. Concn. (mg/Nm³)	Air Temp. (°C)	
											Initial (mg)	Final (mg)	Difference (mg)				
<b>1</b>		29	<b>6</b>	1.00	0.00	0.50	11:22:00	15:28:00	04:06:00	246.00	0.12	1187.58	1188.02	0.44	3.58	<b>3.2</b>	27
<b>2</b>		32	<b>92</b>	2.00	2.00	2.00	11:22:00	15:28:00	04:06:00	246.00	0.49	5166.87	5167.81	0.94	1.91	<b>1.7</b>	27
<b>3</b>	Compactor	26	<b>8</b>	2.00	2.00	2.00	11:22:00	15:28:00	04:06:00	246.00	0.49	1830.97	1831.58	0.61	1.24	<b>1.1</b>	27
<b>4</b>		22	<b>9</b>	1.50	0.00	0.75	11:22:00	15:28:00	04:06:00	246.00	0.18	1842.43	1842.77	0.34	1.84	<b>1.7</b>	27

### **2.9.8 Uncertainty calculations**

Not applicable.